



Government of the Cooperative Republic of Guyana
Environmental Protection Agency



July 26, 2024

Reference #: 20080407-EBFDO

Mr. Ramsaroop


Production Executive

Edward B. Beharry & Company Ltd.

191 Charlotte Street

Lacytown

Georgetown



Dear Mr. Ramsaroop,

Re: Environmental Permit (Varied and Modified) for Power Generation and Fuel Storage Facility to Support the Food Manufacturing Plant

The Environmental Protection Agency (EPA) has prepared an Environmental Permit (Varied and Modified) for the Power Generation and Fuel Storage Facility to Support the Food Manufacturing Plant at 4057 Area "Y", Mandela Avenue, Industrial Site Ruimveldt, Georgetown. The EPA hereby informs you that it has modified some conditions of the Environmental Permit and added some new conditions to enhance their clarity, measurability, and effectiveness (*refer to attachment*).

Please sign the Environmental Permit to indicate your acceptance of its terms and conditions and agreement to comply with the statutory requirements of the Environmental Protection Act, Cap. 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.

Should you have any questions or require further clarifications, please do not hesitate to contact **Ms. Tricia Braithwaite-Environmental Officer, Manufacturing/Industry Department**, by telephone number 225-0506 (Ext. 2365) or email- industry@epaguyana.org.

Yours sincerely,



Attachment: List of permit conditions that have been modified and added.

Ganges St., Sophia, Georgetown, GUYANA.

Tel: (592) 225-5467/5471-5472/6044/6048 | Fax: 225-5481

epa@epaguyana.org | www.epaguyana.org | Environmental Protection Agency - Guyana

"The Environment is Everybody's Business"

LIST OF PERMIT CONDITIONS THAT HAVE BEEN MODIFIED AND ADDED

OLD PERMIT CONDITIONS	NEW & MODIFIED PERMIT CONDITIONS
NIL	1.0 CONSTRUCTION
1.0 OPERATIONS	2.0 OPERATIONS <i>All permit conditions under this section have been updated.</i>
2.0 FUEL HANDLING AND STORAGE	3.0 FUEL HANDLING AND STORAGE <i>All permit conditions under this section have been updated.</i>
3.0 WATER QUALITY	4.0 WATER QUALITY <i>All permit conditions under this section have been updated.</i>
4.0 AIR QUALITY AND NOISE MANAGEMENT	6.0 AIR QUALITY MANAGEMENT <i>All permit conditions under this section have been updated.</i>
	7.0 NOISE QUALITY MANAGEMENT <i>All permit conditions under this section have been updated.</i>
5.0 WASTE MANAGEMENT	9.0 WASTE MANAGEMENT <i>All permit conditions under this section have been updated.</i>
7.0 COMPLIANCE MONITORING AND REPORTING	10.0 COMPLIANCE MONITORING AND REPORTING <i>All permit conditions under this section have been updated.</i>
8.0 INSTITUTIONAL AUTHORITY/ LIABILITIES	11.0 INSTITUTIONAL AUTHORITY/ LIABILITIES <i>All permit conditions under this section have been updated.</i>

Ganges St., Sophia, Georgetown, GUYANA.

Tel: (592) 225-5467/5471-5472/6044/6048 | Fax: 225-5481



epa@epaguyana.org



www.epaguyana.org



Environmental Protection Agency - Guyana

"The Environment is Everybody's Business"



**Environmental
Protection
Agency**

Ganges Street, Sophia,
Georgetown, GUYANA
Tel.: (592)-225-2062 / 1218 / 0506 / 6917
Fax: (592) 225-5481
Email: epa@epaguyana.org

Environmental Permit (Varied & Modified)

Issued under the Environmental Protection Act, Cap. 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000

Reference No.:	20080407- EBFDO
Fee:	Medium (C1) i.e., US\$500 per year
Fee Paid:	US\$2,375 for Four (4) Years, Nine (9) Months (February 2021-October 2025)
Addressee:	Mr. Edward A Beharry Vice Chairman Edward B. Beharry & Company Limited 191 Charlotte Street Lacytown Georgetown
Activity:	Power Generation and Fuel Storage Facility to Support the Food Manufacturing Plant
Varied Activity	Relocation and Construction of a Generator Room and Oil Water Separator

Edward B. Beharry & Company Limited, hereinafter referred to as the "Permit Holder," is hereby authorised in accordance with the Environmental Protection Act, Cap. 20:05, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000, to Operate a Power Generation and Fuel Storage Facility to Support the Food Manufacturing Plant at 4057 Area "Y", Mandela Avenue, Industrial Site Ruimveldt, Georgetown, hereinafter referred to as the "Project," in a manner indicated in the Application for Variance of Environmental Authorisation submitted on April 30, 2024, and subject to the terms and conditions set forth herein under the Environmental Protection Act, Cap. 20:05, Laws of Guyana, and in any existing or forthcoming Regulations made under the said Act, and/or any applicable laws, guidelines, best practices, and standards relevant to this project.

This is a Variance & Modification of Operation Permit (Renewed), Reference No. 20080407- EBFDO, issued on March 23, 2021, and expiring on October 31, 2025.

The Permit Holder, His Servants, Agents, and/ or Sub- Contractors shall comply with the following Terms and Conditions for Operation:

1.0 CONSTRUCTION

- 1.1 Land clearing and disturbance shall be limited to areas where immediate work is taking

place.

- 1.2 Construction works shall **not be executed between 18:00 hrs. to 06:00 hrs.**, on any day, close to communal areas unless, approval is sought from the EPA. This requirement does not apply for large concrete pours or asphalt laying and earth removal where work in the early morning and late evening is required.
- 1.3 Areas for construction material stockpiles and equipment shall be identified.
- 1.4 Stockpile areas shall be downwind to avoid materials being dispersed by wind to sensitive areas. Loading and offloading activities shall, as far as possible, also be confined to this location.
- 1.5 Temporary stockpiles shall not exceed **twenty-four (24) hours** before being removed or transferred to the designated stockpiling areas established by Condition 1.3.
- 1.6 Temporary stockpiles of construction materials, including excavated waste, shall be stored in a secured, designated area and protected from wind and water erosion.
- 1.7 Stockpiles shall not exceed the height of the parameter fence.
- 1.8 Stockpiles, including dusty materials transported to, from, and within the site, shall be enclosed or covered to reduce airborne emissions. Where this is not practical owing to frequent usage, employ wet suppression methods such as watering or erecting dust screens/fences to control emissions.
- 1.9 Install a silt fence **at least 3 meters** from the boundary of any canal, drain, or river to prevent any possible contamination from construction material. The height of the silt fence shall be **no less than 3 meters**; the distance between fence posts shall **not exceed 1.2 meters (4 ft.)**, and fence posts shall be installed at a depth of **at least 0.6 meters (24 inches)**.
- 1.10 Where feasible, pre-mixed, 'ready-mixed' concrete shall be used to reduce dust emissions caused by on-site preparation.
- 1.11 Measures shall be implemented for the removal of any contamination and or siltation of drains during construction.
- 1.12 All construction equipment and machinery shall be maintained in accordance with the manufacturer's specifications to avoid mechanical failures and abnormal noise pollution. Logs and records signed by the appropriate inspecting personnel shall be maintained and made available for inspection by the EPA upon request.
- 1.13 All cutting of wood and mixing of cement shall be done at least 15m from the perimeter drains to minimize pollution.

2.0 OPERATIONS

- 2.1 An application shall be made to the Agency to vary this Permit in instances where it becomes necessary to:

- i. Change the construction, operation, structure, or layout of the facility and all associated buildings;
 - ii. change equipment, machine, apparatus, mechanism, system, or technology serving the facility;
 - iii. change the position and design of any outlet at the point or points of discharge of effluents; or
 - iv. effect any other change outlined in Regulation 20(3) of the Environmental Protection (Authorisations) Regulations
- 2.2 A register of the quantities of fuel and associated hazardous materials stored onsite shall be established and maintained. A summary of the registered information shall be submitted to the Agency as a component of the **Annual Report**.
- 2.3 Inspection and maintenance report for the Cat Diesel Engines shall be established and maintained on-site and made available to the EPA for inspection upon request.
- 2.4 All employees shall be trained on these SOPs outlined in **condition 2.3** above. Training records shall be maintained and made available for inspection by the EPA upon request.
- 2.5 All employees and third parties under the Project's direction shall be made aware of the conditions of the Environmental Authorisation.
- 2.6 Employees shall be equipped with Personal Protective Equipment relevant to the occupational tasks during operation. These Personal Protective Equipment may include but are not limited to:
1. Safety helmets;
 2. Protective respiratory devices
 3. Safety boots with ankle support;
 4. Gloves with reinforced palms and fingers;
 5. Eye protection, such as tightly fitted safety goggles.
- (Employees should at all times be well protected)***
- 2.7 The Permit Holder shall provide training on good environmental practices.
- 2.8 The Guyana Fire Service approval shall be obtained and maintained, and fire protection measures such as fire extinguishers and sand buckets shall be provided in accordance with this approval.
- 2.9 All firefighting equipment shall be maintained and serviced according to the Guyana Fire Service requirements.
- 2.10 Emergency spill clean-up kits shall be maintained at the project for response to spills. Kits must contain absorbent materials, drain seals, and other appropriate tools for clean-up. Kits must be readily available and clearly identified at the Project.
- 2.11 Adhere to the requirements of the **Occupational Safety and Health Act, Cap. 99:01, Laws of Guyana.**

3.0 FUEL HANDLING AND STORAGE

- 3.1 Adopt and comply with the National SOP "Guidance for the Design, Construction, Modification, and Maintenance of Petrol Filling Stations" and any forthcoming code of practice/guidelines pertaining to the operation of fuel storage.
- 3.2 Fuel shall at all times be stored above ground and away from ignition sources. **'No Smoking'** signs shall be posted where fuel is handled or stored.
- 3.3 Existing secondary containment around the fuel tanks shall be inspected monthly for cracks and breakage to ensure they are liquid-tight to withstand hydrostatic pressure of any contained liquid when full.
- 3.4 All secondary containment shall remain sealed, and all piping must enter or exit the containment **over** the wall. Secondary containment shall provide total containment, and no part of the tank infrastructure (e.g., dispenser, filling hoses, and valves) shall protrude outside the containment.
- 3.5 Discharge from the secondary containment is **strictly prohibited**.
- 3.6 Wastewater from the secondary containment shall be channeled to an oil-water separator for treatment.
- 3.7 Fuel storage tanks shall be visually inspected to verify their integrity.
- 3.8 Protection measures for fuel storage tanks, such as painting and coating, shall be maintained to minimize corrosion of fuel tanks.
- 3.9 Overfill protection shall be installed and maintained on all fuel tanks. This may include an automatic shut-off device or an audible or visible overfill alarm.

4.0 WATER QUALITY

- 4.1 Adhere to the provisions of the **Environmental Protection (Water Quality) Regulation, 2000**.
- 4.2 Untreated effluent discharge from the project into the surrounding environment is **strictly prohibited**.
- 4.3 All equipment refuelling shall be conducted on an impervious surface.
- 4.4 The oil-water separator shall be maintained at the point of final discharge from the fuel storage facility's secondary containment.
- 4.5 The project shall maintain the integrity of the existing waterways at all times. Discharges into the environment should be in accordance with the Guyana National Bureau of Standards (GNBS) *Interim Guidelines for Industrial Effluent Discharge into the Environment*. The following are the allowable limits for the general environment

and should not be exceeded:

Parameter	Daily Maximum Concentration	Units	Sample type	Frequency of Analysis
pH	5.0-9.0		Grab	Annually
Temperature	<40	°C	Grab	
Total Suspended Solids (TSS)	< 100	mg/L	Grab	
Total Petroleum Hydrocarbon (TPH)	< 40	mg/L	Grab	

Water Quality Monitoring shall be conducted at the final discharge point from the oil-water separator/s or approved sampling point/s, in accordance with the parameters listed above, by trained personnel utilizing calibrated equipment. Records shall be maintained and submitted to the EPA as a component of the **Annual Report**.

- 4.6 Fuel/lubricants, including waste oils, shall not be drained from equipment onto the ground or into waterways.
- 4.7 Interceptor drains shall be maintained on-site. These must be adequately sloped to collect storm flow.

5.0 AIR QUALITY MANAGEMENT

- 5.1 Adhere to the provisions of the **Environmental Protection (Air Quality) Regulations, 2000**.
- 5.2 Air quality monitoring shall be conducted **annually** at the boundary of the property during normal operations to assess the levels of the following air pollutants in accordance with the WHO Air Quality Guidelines 2021:

Air Pollutant	Averaging Time	Maximum Permissible Level	Type of Monitoring
Carbon Monoxide	24 h	4 mg/m ³	Ambient
Nitrogen Dioxide	24 h	25 µg/m ³	Ambient
Sulphur Dioxide	24 h	40 µg/m ³	Ambient
PM _{2.5}	24 h	15 µg/m ³	Ambient
PM ₁₀	24 h	45 µg/m ³	Ambient

Air Quality monitoring shall be conducted in accordance with the parameters listed above by trained personnel utilizing calibrated equipment. Records shall be maintained

and submitted to the EPA as a component of the **Annual Report**.

- 5.3 The height of the Generator's exhaust stack from the base to the point of emission shall not be less than 2.5 metres above the tallest building within an 800 metres radius of the Generator's house.
- 5.4 In the event of inefficiencies which may result in visible or abnormal emissions to air, the operator shall:
- 6.5.1 Investigate and undertake remedial action immediately;
 - 6.5.2 Adjust the process or activity to minimise those emissions; and
 - 6.5.3 Record the events and actions taken. This shall be submitted in the annual report.

6.0 NOISE QUALITY MANAGEMENT

- 6.1 Adhere to the provisions of the **Environmental Protection (Noise Management) Regulations, 2000**.
- 6.2 All significant noise-producing equipment, such as generators, shall be equipped with silencers or mufflers and/or be enclosed in suitable acoustic enclosures where necessary to reduce noise levels impacting the surrounding environment to achieve compliance with Guyana National Bureau of Standards (GNBS) requirement.
- 6.3 All generators and machines/equipment shall be serviced in accordance with the manufacturer's specifications to ensure efficiency and reduce the level of noise produced. A summarised maintenance report shall be submitted as a component of the **Annual Report**.
- 6.4 Noise emissions shall be monitored at a distance of 15 m (50ft) from the source or at the property boundary, whichever is closer, **annually** to determine compliance with Guyana National Bureau of Standards (GNBS) *Guidelines for Noise Emissions into the Environment*, not exceeding the *industrial* limits listed below:

Industrial Limits: 100 dB (Day-time (06:00 h -18:00 h))
80dB (Night- time (18:00 h - 06:00 h))

Noise Quality monitoring shall be conducted in accordance with the parameters listed above by trained personnel utilizing calibrated equipment. Records of each monitoring exercise shall be maintained, and results shall be submitted to the Agency as a component of the Project's **Annual Report**.

7.0 HAZARDOUS WASTE MANAGEMENT

- 7.1 Adhere to the provisions of the **Environmental Protection (Hazardous Waste Management) Regulation 2000**.
- 7.2 All hazardous waste shall be stored in containers appropriate for the waste stream. That is:

a) Sealed Plastic Containers

- i. Water-based wastes
- ii. Fountain Solutions, Pre-Press

b) Sealed Metal Containers

- i. Solvents and Petroleum- based products
- ii. Waste ink, Press-wash, Oil, and Oily Absorbents

7.3 All hazardous waste containers shall be labelled with the following:

- i. The words **"Hazardous Waste"**
- ii. The type of waste
- iii. Beginning accumulation date-

7.4 All waste oil containers shall be labelled with the following:

- i. The words **"Waste Oil or "Used oil"**
- ii. Beginning accumulation date

7.5 All hazardous waste shall be stored in a covered, bunded area. This area shall include the following:

- i. **Signage- "Hazardous Waste Storage Area"**
- ii. Low traffic
- iii. No floor drains
- iv. Bunded area shall provide 110% containment of the largest volume stored therein.

7.6 All hazardous waste shall be disposed of and/or treated by an EPA-authorised Hazardous Waste Disposal Facility. The Project shall retain a signed copy of the **Waste Manifest Form** submitted by the Hazardous Waste Transporter, for a period of three years. The copies shall be maintained on-site, and an annual summary of these records shall be submitted to the EPA as a component of the **Annual Report**.

8.0 WASTE MANAGEMENT

8.1 In accordance with the **Environmental Protection (Litter Enforcement) Regulations, 2013**, promote good sanitation and solid waste disposal practices on site. Covered garbage receptacles shall be placed upon impervious bases at strategic locations, both within and outside the facility.

8.2 Burning of solid waste **is strictly prohibited**. All solid waste shall be disposed of by an EPA-Authorised Waste Disposal Company.

8.3 Good housekeeping, sanitary, and hygienic practices shall be maintained at all times. The facility's drains and surroundings shall be kept free of vegetation and litter.

8.4 Promote waste minimization and the reuse and/or recycling of waste and other materials where practical.

8.5 Waste collection areas shall be kept clean. Dry methods shall be used when cleaning around waste handling and disposal areas (e.g., sweeping, use of absorbents).

- 8.6 The Permit Holder shall maintain a septic tank system on site in accordance with the Guyana National Bureau of Standards (GNBS) *Code of Practice for the Design and Construction of Septic Tanks and Associated Secondary Treatment and Disposal Systems*:
- i) The septic tank shall not be located within 1.5 meters of a building or property boundary;
 - ii) septic tanks shall be installed with a sand and charcoal filter bed or other appropriate design for further treatment; and
 - iii) shall be accessible for cleaning and de-sludging.

- 8.7 Any modification to the Septic tank shall be in accordance with the Guyana National Bureau of Standards (GNBS) *Code of Practice for the Design and Construction of Septic Tanks and Associated Secondary Treatment and Disposal Systems*.

9.0 COMPLIANCE MONITORING AND REPORTING

- 9.1 Notify the Environmental Protection Agency **within one (1) hour** of the occurrence of any environmental emergencies (e.g., oil spills, biohazardous materials/wastes spill, sudden onset disaster, natural, technological, or human-induced factors that cause or threaten to cause severe environmental damage as well as harm to human health or livelihood).
- 9.2 Monitor the implementation of the conditions of this Permit, insofar as they involve adherence by your employees and all third parties under your direction.
- 9.3 Notify the Agency in writing of any change of name or ownership of the Permit Holder's facility within **thirty (30) days** after the change occurs.
- 9.4 Notify the Agency **within twenty-one (21) days** in the event of death, bankruptcy, liquidation, or receivership of the Permit Holder or if the Company becomes a party to an amalgamation.
- 9.5 Maintain and submit to the Agency records of the type, composition, and quantity of contaminant released (i.e., any solid, liquid, gas, odour, sound, vibration, radiation, heat, or combination of any of them).
- 9.6 Submit an **Annual Report** to the EPA on your compliance with this Permit on or before **March 31 of each year**.
- 9.7 Report to the Agency any non-compliance(s) with the Environmental Permit:
- i. Within **twenty-four (24) hours** of the time the Holder of the Environmental Permit becomes aware of the non-compliance outlining the anticipated manner in which human health or the environment may be impacted.
 - ii. Within **seventy-two (72) hours** of the time the Holder of the Environmental Permit becomes aware of the non-compliance, submit to the Agency a written

report containing a description of the non-compliance, its cause, the period of non-compliance including exact dates and time, and the anticipated time it is expected to continue if the non-compliance(s) has not been corrected.

- 9.8 Comply with any lawful directions given by the EPA from time to time in furtherance of the implementation of any international or other obligation for the environmental protection of Guyana.
- 9.9 It is the responsibility of the Permit Holder to ensure the permitted activity and premises are secured and that all practicable steps necessary to prevent fires, explosions, leaks, or suspected leaks and spills at the permitted premises are taken.


10.0 INSTITUTIONAL AUTHORITY/ LIABILITIES

- 10.1 The Permit Holder shall be liable for any material environmental harm caused by polluting the environment, pursuant to s. 39 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.2 The Permit Holder shall be liable for any serious environmental harm caused by polluting the environment, pursuant to s. 39 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.3 The Permit Holder shall be liable for any activity that causes or is likely to cause pollution of the environment unless all reasonable and practicable measures are taken to prevent or minimize any resulting adverse effect, pursuant to s. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.4 The Permit Holder shall be liable for discharging, causing, or permitting the entry into the environment, of any contaminant in any amount, concentration, or level in excess of that prescribed by the regulations or stipulated by this Environmental Permit, pursuant to s. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.5 The Permit Holder shall be liable to compensate any person who suffers any loss or damage as a result of contravening conditions 10.3 and 10.4 of this Environmental Permit, pursuant to s. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.6 The Permit Holder shall not be indemnified by the Agency for any activity that causes or is likely to cause pollution to the environment, resulting from adverse effects through the discharge, of any contaminant in any amount, concentration, ultra-hazardous substances, chemicals or otherwise, and shall be rendered liable to prosecution and to penalties prescribed under the Environmental Protection Act and Regulations.
- 10.7 The Permit Holder shall be liable for any gross negligence or willful misconduct caused by the Permit Holder, his Servants, and/or Agents, to the environment, biodiversity, protected species, and natural habitat with respect to any release, discharge, or spill, of contaminant fluids, oil or lubricants.

- 10.8 Shall the Permit Holder contravene or be likely to contravene any condition of this Permit, the Agency (EPA) may serve on him an Enforcement Notice in accordance with Section 26 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.9 Where it appears to the Agency that the Permit Holder is engaged in any activity that may pose a serious threat to natural resources or the environment or a risk of serious pollution of the environment or any damage to public health, the EPA may issue to the Permit Holder a Prohibition Notice, which may order him to immediately cease the offending activity, in accordance with Section 27 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 10.10 The EPA reserves the right to conduct regular inspections of the Permit Holder's activities as part of its monitoring and enforcement requirements under the Environmental Protection Act, Cap 20:05, the Environmental Protection (Amendment) Act, 2005, and Environmental Protection (Authorisations) Regulations, 2000.
- 10.11 The Permit Holder, His Servants, and/or Agents shall at all times, allow entry to the permitted facility to any Officer designated by the EPA for the purposes of conducting inspections or any other legitimate business of the Agency. Pursuant to Section 38 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana, it is an offense to assault, obstruct or hinder an authorised person in the execution of his/her duty under the said Act or its Regulations and the Permit Holder shall be liable to penalties prescribed under paragraph (c) of the Fifth Schedule for doing so.
- 10.12 The EPA has the right to modify, cancel or suspend this Permit for breach of any of the terms and conditions contained herein.
- 10.13 **This Environmental Permit (Varied & Modified) is not the final consent; all relevant Permissions shall be obtained from other regulatory bodies for continued operation.**
- 10.14 This Environmental Permit (Varied & Modified) is effective for the period stipulated herein; **February 2021- October 2025.**
- 10.15 This Environmental Permit (Varied & Modified) shall remain valid until **October 31, 2025**, unless otherwise suspended, canceled, modified, or varied, in accordance with the provisions of this Permit or the Environmental Protection Act, Cap. 20:05, Laws of Guyana, Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.
- 10.16 This Permit shall be renewed by submitting a completed *Application Form for Renewal of Environmental Authorization* to the Agency at least six months before this Permit expires, that is, no later than **April 31, 2025.**
- 10.17 Any late submission of a renewal application after the specified date as stated above may require the Permit Holder to pay, in addition to the renewal fee, a late penalty fee (accruing at the time such obligation was first owed for renewal) at a rate of **two thousand dollars (GY\$2000.00) per day for every business day late, until**


such renewal application is submitted to the Agency, without prejudice to any other rights of the Permit Holder in connection therewith.

- 10.18 Failure to comply with the requirements of this Permit or with applicable laws and regulations, whether existing or forthcoming, shall render the Permit Holder liable to prosecution and to penalties, inclusive of civil penalties, injunctive relief, and imprisonment, as prescribed under the Environmental Protection Act, Cap. 20:05, Laws of Guyana, the Environmental Protection Regulations, and other applicable Laws of Guyana.

Signed by  on behalf of the Environmental Protection Agency.
Kemraj Parsram
Executive Director

Date 2024.07.26

I hereby accept the above terms and conditions upon which this Environmental Permit (Varied & Modified) is granted and agree to abide by the Environmental Protection Act, Cap. 20:05, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000, and any existing or forthcoming regulations, guidelines, best practices, and standards made under this Act.

NAME:	Raymond Ramsaroop
SIGNATURE:	
DESIGNATION:	Production Executive
DATE:	2025-02-12



2000
1000
500
0