



**Environmental
Protection
Agency**

Ganges Street, Sophia,
Georgetown, GUYANA
Tel.: (592) 225-0506
Fax: (592) 225-5481
Email: epa@epaguyana.org
Website: <http://www.epaguyana.org>

Environmental Permit (Renewed)

Issued under the Environmental Protection Act, Cap. 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000

Reference No.:	20150422-MCGLS
Fee:	Medium (C1) i.e., US\$500 per year
Fee Paid:	US\$ 1500 for three (3) Years (April 2023 – March 2026)
Addressee:	Machinery Corporation of Guyana Limited (MACORP) 26, Providence, East Bank Demerara.
Activity:	Operation of a Fuel Storage Facility

Machinery Corporation of Guyana Limited (MACORP), hereinafter referred to as the “Permit Holder”, is hereby authorised in accordance with the Environmental Protection Act, Cap. 20:05, Laws of Guyana, Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000, to Operate a Fuel Storage Facility, 26 Providence, East Bank Demerara, hereinafter referred to as “the Project”, in a manner indicated in the Application for Renewal of an Environmental Authorisation submitted on September 28, 2022 and subject to the terms and conditions set forth herein under the Environmental Protection Act, Cap. 20:05, existing and/or forthcoming regulations made under the said Act, and/or any other applicable laws, guidelines, best practices, approvals, directives and standards relevant to this project.

This is a Renewal of the Environmental Permit, Reference No. 20150422-MCGLS, issued on August 7, 2017, which expired on July 31, 2022. The Environmental Permit (Renewed) is issued pursuant to the Environmental Protection (Authorisation) Regulations, 2000.

The Permit Holder, His Servants, Agents and/or Sub-Contractor(s) shall comply with the following Terms and Conditions for Operation:

1.0 OPERATION

- 1.1 Make an application to the Agency to vary this Permit in instances where it becomes necessary to:
 - i. change the construction, operation, structure, or layout of the facility and all associated buildings;
 - ii. change equipment, machine, apparatus, mechanism, system or technology serving the facility;
 - iii. change the position and design of any outlet at the point or points of discharge of effluents; or
 - iv. effect any other change outlined in 20(3) of the Environmental Protection (Authorisations) Regulations.
- 1.2 Submit to the EPA the following approvals and documents for the Storage of Diesel on site, by **May 31, 2023**, unless otherwise directed by the EPA:
 - i. An approved site plan for storage of fuel from Central Housing and Planning Authority (CH&PA)
 - ii. An Emergency Preparedness Plan
 - iii. Updated Guyana Fire Service License
 - iv. Updated Guyana Energy Agency License
 - v. Updated Business Registration
 - vi. Updated Guyana National Bureau of Standards License
- 1.3 Guyana Fire Service Approval shall be maintained annually and submitted as a component of the Annual Report.
 - 1.3.1 The Project shall maintain fire prevention and control equipment in accordance with the Guyana Fire Service Approval.
- 1.4 Develop and implement an appropriate Operation and Maintenance Standard Operation Procedure (SOP) for the Project. The SOP shall address all aspects of the on-going fuel storage facility and must include but not be limited to:
 - i. maintenance and inspection schedules;
 - ii. monitoring/investigation procedures;
 - iii. emergency response plan;
 - iv. management of waste oil;
 - v. fuel transfer operations; and
 - vi. training of staff on the SOPs.
 - 1.4.1 The SOP shall be submitted to the EPA upon request.
- 1.5 Emergency spill cleanup kits shall be readily available, accessible and maintained at the Project Site. Kits shall contain absorbent materials, drain seals and other appropriate tools for clean-up of potential spills.
- 1.6 Adhere to the Drainage & Irrigation Laws of Guyana Cap.64:03.

Environmental Permit (Renewed) Ref. No. 20150422-MCGLS

Issued under of the Environmental Protection Act, Cap 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.

- 1.7 Maintain an impervious secondary containment wall around the aboveground fuel storage tank, creating a temporary holding area in the event of accidental spillage.
 - 1.7.1 The containment wall shall be fully sealed to prevent spillage into the receiving drainage system.
 - 1.7.2 The containment wall for areas with solitary tank shall have the capacity to provide 110% containment of the fuel tank.
- 1.8 All secondary containment shall remain sealed and all piping shall enter or exit the containment over the wall. Secondary containment shall provide total containment, and no part of the tank infrastructure (e.g., dispenser, filling hoses and valves) shall protrude outside the containment.
- 1.9 Existing secondary containment around the fuel tank shall be inspected monthly for cracks and breakage to ensure they are liquid tight to withstand hydrostatic pressure of any contained liquid when full. A summarised inspection report shall be kept and submitted to the Agency upon request.
- 1.10 Route pipelines from tanks to offset filling points, dispensing equipment and vent pipes below the ground surface. Pipelines shall not be located under buildings and shall be accessible for easy maintenance.
- 1.11 Maintain leak detection mechanisms, such as:
 - i. An overflow alarm on tanks;
 - ii. A gauging system;
 - iii. Dipstick measurements; or
 - iv. Sensors installed on walls of tank.
- 1.12 Strictly adhere to the Occupational, Health and Safety (OHS) Act, Cap. 99:10, Laws of Guyana.
- 1.13 Make all employees, and third parties under your direction, aware of the conditions of the Environmental Authorisation and provide training on good environmental practices.

2.0 FUEL HANDLING AND STORAGE

- 2.1 Adopt and comply with the National Standard "*Guidance for the Design, Construction, Modification, and Maintenance of Petrol Filling Stations*" and any forthcoming code of practice/guidelines pertaining to the operation of fuel storage.
- 2.2 A register of the quantities of fuel stored onsite shall be maintained. A summary of the registered information shall be kept and submitted to the EPA upon request.
- 2.3 Fuel shall at all times be stored aboveground, in a cool, dry place and away from



ignition sources.

- 2.4 **'No Smoking'** signs shall be maintained where fuel is handled or stored.
- 2.5 Routinely monitor and maintain aboveground storage tanks to prevent leaks. Areas to inspect include tank foundation, connections, coatings, tanks walls, and piping systems. Inspection reports shall be kept and provided upon request by the Agency.
- 2.6 Protection measures for fuel storage tanks such as painting and coating shall be maintained to minimise corrosion of fuel tanks.
- 2.7 Maintenance and/or repair of fittings, pipes and hoses shall be conducted in accordance to manufacturer's specifications.
- 2.8 Overfill protection shall be maintained on all fuel tanks. This may include an automatic shut off device or an audible or visible overfill alarm.
- 2.9 The safe fill level shall be clearly identified on the gauge and set at 90% to prevent overfilling. In the event of overfilling, all discharges shall be released into the containment bund.
- 2.10 The Best Available Technology/ Technique (BAT) shall be maintained to capture fuel lost during the unloading of fuel to storage tanks and refueling of equipment.
- 2.11 Secondary containment, drip trays or other overflow and drip containment measures shall be maintained at connection points or other possible overflow points.

3.0 WATER QUALITY

- 3.1 Strictly adhere to the provisions of the **Environmental Protection (Water Quality) Regulation, 2000.**
- 3.2 Maintain oil-water separators at strategic locations on the storage facility through which all effluents shall pass before the final discharge.
- 3.3 Perimeter drains shall be maintained on site and shall be adequately sloped to collect storm flow.
- 3.4 Maintain the integrity of the existing waterways at all times. Discharges into the environment shall be in accordance with the Guyana National Bureau of Standards (GNBS) *Interim Guidelines for Industrial Effluent Discharge into the Environment*. The following are the allowable limits for this type of project and shall not exceed:
 - i. Total Suspended Solid (TSS) < 100 mg/L;
 - ii. Oil and Grease < 10 mg/L; and
 - iii. Total Petroleum Hydrocarbon (TPH) < 40 mg/L.

- 3.5 The results of the water quality test shall be submitted to the Agency as part of the Annual Report.
- 3.6 Fuel/lubricants including waste oils shall not be drained from equipment onto the ground or into waterways.
- 3.7 Avoid soil and water contamination from fuel, grease, waste oils and other petroleum products. Store all oils, fuel, paints and chemicals in a designated area away from watercourses.

4.0 AIR QUALITY AND NOISE MANAGEMENT

- 4.1 Strictly adhere to the provisions of the **Environmental Protection (Air Quality) Regulations, 2000** and the **Environmental Protection (Noise Management) Regulations, 2000**.
- 4.2 Comply with the Guyana National Bureau of Standards (GNBS) *Guidelines for Noise Emissions into the Environment*. Sound levels from noise-making devices shall not exceed the limits below, at a distance of 15 metres (50ft) from the source or property boundary, whichever is closer.

Commercial Limits: 80 dB (Day-time (06:00 h -18:00 h))
65 dB (Night- time (18:00 h - 06:00 h))

- 4.3 Handle and store liquid fuel in such a manner so as to prevent the emission of offensive odours.
- 4.4 Monitor any malfunction or breakdown leading to abnormal emissions promptly. Adjust process until normal operations can be restored.
- 4.5 All significant noise-producing equipment, such as generators, shall be equipped with silencers or mufflers and/or be enclosed in suitable acoustic enclosures to reduce noise levels impacting the surrounding environment and to achieve compliance with Guyana National Bureau of Standards (GNBS) requirement.
- 4.6 All generators and machines/equipment shall be serviced in accordance with manufacturers' specifications to ensure efficiency and reduce the level of noise produced. A summarised maintenance report shall be submitted as a component of the Annual Report.
- 4.7 Exhaust stacks of the generator(s) shall be **at least 2 meters above** the generator house or the tallest building nearby, to minimise adverse fumes/soot impacts to the contiguous areas.

5.0 WASTE MANAGEMENT

- 5.1 In accordance with the **Environmental Protection (Litter Enforcement) Regulations, 2013**, promote good sanitation and solid waste disposal practices on



site; covered garbage receptacles shall be placed at strategic locations at the facility, and waste shall be collected and disposed at an approved waste disposal facility.

5.2 Burning of waste is **strictly prohibited**.

5.3 Solid waste receptacles shall be covered when not in use.

5.4 Good house-keeping, sanitary, and hygienic practices shall be maintained at all times. The facility surroundings shall be kept free of vegetation and litter.

6.0 HAZARDOUS WASTE MANAGEMENT

6.1 Strictly adhere to the provisions of the **Environmental Protection (Hazardous Waste Management) Regulation 2000**.

6.2 All hazardous waste containers shall be labelled with the following:

- i. The words "**Hazardous Waste**";
- ii. The type of waste; and
- iii. Beginning of accumulation date.

6.3 All hazardous waste shall be treated by an EPA authorised Hazardous Waste Treatment Facility.

6.4 Ensure that appropriate clean – up equipment such as spill trays, oil spill clean – up recovery pump, oil spill dispersant spray system or absorbent pads are readily accessible during refueling exercise.

7.0 COMPLIANCE MONITORING AND REPORTING

7.1 Notify the Environmental Protection Agency **within one (1) hour** of the occurrence of any environmental emergencies (e.g., oil spills, hazardous materials/wastes spills, sudden onset disaster, natural, technological or human-induced factors that cause or threaten to cause severe environmental damage as well as harm to human health or livelihood).

7.2 All near misses, spills and unwanted/accidental discharges, **amounting to less than imperial five (5) gallons**, must be recorded and reported to the Agency as a component of the Annual Report.

7.3 Discharges of contaminants amounting to **five (5) imperial gallons or more** must be reported to the Agency by submitting an "*Incident Notification Form for Spills in Onshore Operations*" using the most recent template provided by the Agency, **within forty-eight (48) hours** of the incident. A follow-up incident notification form shall be submitted **within seventy-two (72) hours** of the submission of the initial notification form (a total of five days after the discharge of contaminants).

Environmental Permit (Renewed) Ref. No. 20150422-MCGLS

Issued under of the Environmental Protection Act, Cap 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.

- 7.4 Notify the Agency in writing of any change of name or ownership of the Permit Holder's facility **within thirty (30) days** after the change occurs.
- 7.5 Notify the Agency **within twenty-one (21) days** in event of death, bankruptcy, liquidation or receivership of the Permit Holder or if the Company becomes a party to an amalgamation.
- 7.6 Maintain and submit to the Agency records of the type, composition and quantity of contaminant released (i.e., any solid, liquid, gas, odor, sound, vibration, heat or combination of any of them).
- 7.7 Submit **Annual Reports** to the EPA on your compliance with this Permit on or before **March 31**, each year.
- 7.8 Report to the Agency any non-compliance(s) with the Environmental Permit (Renewed):
- I. **Within twenty-four (24) hours** of the time the Holder of the Environmental Permit (Renewed) for operation becomes aware of the non-compliance outlining the anticipated manner in which human health or the environment may be impacted.
 - II. **Within seventy-two (72) hours** of the time the Holder of the Environmental Permit (Renewed) becomes aware of the non-compliance, submit to the Agency a written report containing a description of the non-compliance, its cause, the period of non-compliance including exact dates and time and the anticipated time it is expected to continue if the non-compliance(s) has not been corrected.
- 7.9 Comply with any lawful directions given by the EPA from time-to-time in furtherance of the implementation of any international or other obligation for the environmental protection of Guyana.

8.0 INSTITUTIONAL AUTHORITY/ LIABILITIES

- 8.1 The Permit Holder shall be liable for any material environmental harm caused by polluting the environment, pursuant to S. 39 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.2 The Permit Holder shall be liable for any serious environmental harm caused by polluting the environment, pursuant to S. 39 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.3 The Permit Holder shall be liable for any activity that causes or is likely to cause pollution of the environment unless all reasonable and practicable measures are taken to prevent or minimize any resulting adverse effect, pursuant to S. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.

Environmental Permit (Renewed) Ref. No. 20150422-MCGLS


Issued under of the Environmental Protection Act, Cap 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.

- 8.4 The Permit Holder shall be liable for discharging, causing or permitting the entry into the environment, of any contaminant in any amount, concentration or level excess of that prescribed by the regulations or stipulated by this Environmental Permit (Renewed), pursuant to S. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.5 The Permit Holder shall be liable to compensate any person who suffers any loss or damage as a result of contravening conditions 8.3 and 8.4 of this Environmental Permit (Renewed), pursuant to S. 19 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.6 The Permit Holder shall not be indemnified by the Agency for any activity that causes or is likely to cause pollution to the environment, resulting from adverse effects through the discharge, any contaminant in any amount, concentration, ultra-hazardous substances, chemicals or otherwise, and shall be rendered liable to prosecution and to penalties prescribed under the Environmental Protection Act and Regulations.
- 8.7 The Permit Holder shall be liable of any gross negligence or willful misconduct caused by the Permit Holder, his Servants and/or Agents, to the environment, biodiversity, protected species and natural habitat with respect to any release, discharge, or spill, of contaminant fluids, oil or lubricants.
- 8.8 Should the Permit Holder contravene or be likely to contravene any condition of this Permit, the Agency (EPA) may serve on him an Enforcement Notice in accordance with Section 26 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.9 Where it appears to the Agency that the Permit Holder is engaged in any activity that may pose a serious threat to natural resources or the environment, or a risk of serious pollution of the environment or any damage to public health, the EPA may issue to the Permit Holder a Prohibition Notice, which may order him to immediately cease the offending activity, in accordance with Section 27 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana.
- 8.10 The EPA reserves the right to conduct regular inspections of the Permit Holder's activities as part of its monitoring and enforcement requirements under the Environmental Protection Act, Cap 20:05, and the Environmental Protection (Amendment) Act, 2005, and Environmental Protection (Authorisations) Regulations, 2000.
- 8.11 The Permit Holder, His Servants and/or Agents shall at all times, allow entry to the permitted facility to any Officer designated by the EPA for the purposes of conducting inspections or any other legitimate business of the Agency. Pursuant to Section 38 of the Environmental Protection Act, Cap. 20:05, Laws of Guyana, it is an offence to assault, obstruct or hinder an authorised person in the execution of his/her duty under the said Act or its Regulations and the Permit Holder shall be liable to penalties prescribed under paragraph (c) of the Fifth Schedule for doing so.

- 8.12 The EPA has the right to modify, cancel or suspend this Permit for breach of any of the terms and conditions contained herein.
- 8.13 **This Environmental Permit is not the final consent, all relevant Permissions shall be obtained from other regulatory bodies for continued operation.**
- 8.14 This Environmental Permit (Renewed) is effective for the period stipulated herein, **April 2023 to March 2026.**
- 8.15 This Environmental Permit (Renewed) shall remain valid until **March 31, 2026**, unless otherwise suspended, cancelled, modified or varied, in accordance with the provisions of this Permit or the Environmental Protection Act, Cap. 20:05, Laws of Guyana, Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.
- 8.16 This Permit shall be renewed by submitting a completed Application form for Renewal of Environmental Authorisation to the Agency at least **six (6) months** before this Permit expires, that is, no later than **September 30, 2025.**
- 8.17 Any late submission of renewal application (s) after the specified date as stated above, may require the Permit Holder to pay, in addition to renewal fee, a late penalty fee (accruing at the time such obligation was first owed for renewal) at a rate of **two thousand dollars (GY\$2000.00) per day for every day late, until such renewal application is submitted to the Agency**, without prejudice to any other rights of the Permit Holder in connection therewith.
- 8.18 Failure to comply with the requirements of this Permit or with applicable laws and regulations, whether existing or forthcoming, shall render the Permit Holder liable to prosecution and to penalties, inclusive of civil penalties, injunctive relief and imprisonment, as prescribed under the Environmental Protection Act, Cap. 20:05, Laws of Guyana, the Environmental Protection Regulations and other applicable Laws of Guyana.

Environmental Permit (Renewed) Ref. No. 20150422-MCGLS

Issued under of the Environmental Protection Act, Cap 20:05, Laws of Guyana, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000.

Signed by  on behalf of the Environmental Protection Agency.
Kemraj Parsram
Executive Director

Date 2023-04-25

I hereby accept the above terms and conditions upon which this Environmental Permit (Renewed) is granted and agree to abide by the Environmental Protection Act, Cap. 20:05, the Environmental Protection (Amendment) Act, 2005, and the Environmental Protection (Authorisations) Regulations, 2000, and any existing or forthcoming regulations, guidelines, best practices and standards made under this Act.

NAME	Joel Latchman
DATE	2023-04-26
SIGNATURE	J. Latchman
DESIGNATION	Driver

